

Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD  
 Environment Protection Licence Number - 12490  
 Pollution Monitoring - Nitrogen Oxides  
 Sample Period - December 2014 - November 2015



Sample Location	Data Sort	Dec-14	Jan-15	Feb-15	Mar-15	Apr-15	May-15	Jun-15	Jul-15	Aug-15	Sep-15	Oct-15	Nov-15	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	23	22	34	37	36	38	39	37	31	26	29	31	32	mg/m3	-	-
EPA Identification No. 1	Minimum	18	10	27	27	27	31	35	27	28	11	12	1	1	mg/m3	-	-
Turbine Stack 1	Maximum	48	50	43	45	51	49	44	50	48	51	51	51	51	mg/m3	51	100
Sample Point:	Average	15	13	23	22	24	24	23	23	26	28	24	22	22	mg/m3	-	-
EPA Identification No. 2	Minimum	9	1	14	12	15	15	10	3	15	6	9	2	1	mg/m3	-	-
Turbine Stack 2	Maximum	35	31	46	43	51	51	48	46	40	49	51	51	51	mg/m3	51	100
Sample Point:	Average	17	17	26	29	26	31	30	32	33	31	31	28	28	mg/m3	-	-
EPA Identification No. 3	Minimum	1	1	14	18	9	18	19	24	22	10	19	5	1	mg/m3	-	-
Turbine Stack 3	Maximum	50	38	49	51	51	48	40	50	48	51	42	51	51	mg/m3	51	100
Sample Point:	Average	20	18	32	31	30	31	30	29	30	31	29	29	28	mg/m3	-	-
EPA Identification No. 4	Minimum	15	6	28	21	10	7	7	23	25	13	6	6	6	mg/m3	-	-
Turbine Stack 4	Maximum	40	43	48	38	46	51	46	51	51	51	49	49	51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		<b>Note:</b> "-" indicates no Unit run for reporting period	
Date Data Downloaded		15/01/2015	2/02/2015	26/03/2015	15/04/2015	1/05/2015	5/06/2015	3/07/2015	24/08/2015	24/08/2015	16/09/2015	19/10/2015	15/12/2015				
Date Data Published		5/02/2015	5/02/2015	27/03/2015	22/04/2015	15/05/2015	19/06/2015	17/07/2015	30/08/2015	30/08/2015	29/09/2015	30/10/2015	30/12/2015				