

Environment Protection Licence Licensee - Origin Energy Uranquinty Power PTY LTD  
 Environment Protection Licence Number - 12490  
 Pollution Monitoring - Nitrogen Oxides  
 Sample Period - December 2015 - November 2016



Sample Location	Data Sort	Dec-15	Jan-16	Feb-16	Mar-16	Apr-16	May-16	Jun-16	Jul-16	Aug-16	Sep-16	Oct-16	Nov-16	Year To date	Units of Measure	Licence Limit Conditions	
																mg/m3	Percentile
Sample Point:	Average	26	21	22	23	23	26	26	28	26	26	28		25	mg/m3	-	-
EPA Identification No. 1	Minimum	10	1	6	4	4	10	17	21	22	22	15		1	mg/m3	-	-
Turbine Stack 1	Maximum	50	51	50	48	50	51	49	46	50	48	45		51	mg/m3	51	100
Sample Point:	Average	22	16	18	20	21	23	27	29	29	28	33		24	mg/m3	-	-
EPA Identification No. 2	Minimum	1	1	1	2	1	2	16	13	27	26	25		1	mg/m3	-	-
Turbine Stack 2	Maximum	50	49	50	46	49	50	51	51	47	35	51		51	mg/m3	51	100
Sample Point:	Average	27	24	26	28	29	31	29	29	28	27	30		28	mg/m3	-	-
EPA Identification No. 3	Minimum	10	1	4	5	8	10	26	23	26	25	24		1	mg/m3	-	-
Turbine Stack 3	Maximum	48	49	49	49	49	50	45	49	40	39	44		50	mg/m3	51	100
Sample Point:	Average	27	21	23	25	28	29	27	26	28	27	29		26	mg/m3	-	-
EPA Identification No. 4	Minimum	8	1	1	4	2	9	21	22	24	24	23		1	mg/m3	-	-
Turbine Stack 4	Maximum	50	50	44	48	51	50	50	44	46	44	49		51	mg/m3	51	100
Date Data Sampled		Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous		<b>Note:</b> "-" indicates no Unit run for reporting period	
Date Data Downloaded		4/01/2016	2/02/2016	2/03/2016	5/04/2016	2/5/2/16	2/06/2016	2/06/2016	1/07/2016	1/09/2016	10/10/2016	11/11/2016					
Date Data Published		15/01/2016	4/02/2016	31/05/2016	31/05/2016	31/05/2016	25/07/2016	8/08/2016	8/08/2016	17/10/2016	17/10/2016	20/11/2016					